

**Drinking Water Quality and Compliance
Annual Notice to Consumers
Town of Lampman Distribution System
Station Number SK05ND0008**

Introduction

The Water Security Agency and the Ministry of Environment requires that at least once each year waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Minister’s Order or Permit to Operate a waterworks. The following is a summary of the Town of Lampman water quality and sample submission compliance record for the January 1, 2025 – December 31, 2025 time period. This report was completed on June 12, 2026. Readers should refer to Water Security Agency’s [Municipal Drinking Water Quality Monitoring Guidelines, June 2015, EPB 502](#) for more information on minimum sample submission requirements and the meaning of type of sample. Permit requirements for a specific waterworks may require more sampling than outlined in the department’s monitoring guidelines. If consumers need more information on the nature and significance of specific water tests, for example, “what is the significance of Selenium in a water supply”, more detailed information is available from: http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index_e.html.

Water Quality Standards

Bacteriological Quality

Parameter	Limit	Regular Samples Required	Regular Samples Submitted	# of Positive Regular Sample Results
Total Coliform	Zero organisms/100 mL	52	52	0
E. Coli	Zero organisms/100 mL	52	52	0

Water Disinfection –

Chlorine Residual in Distribution System for Test Results Submitted with Bacteriological Samples

Parameter	Minimum Limit	Total Chlorine Residual Range	Free Chlorine Residual Range	# of Tests Required	# of Tests Submitted	# Of Tests Not Meeting Requirements
Chlorine Residual	0.1 mg/L free OR 0.5 mg/L total	(.23-5.05)	(.11 – 4.18)	52	52	0

Water Disinfection - Free Chlorine Residual for Water Entering Distribution System from Waterworks Records-From Water Treatment Plant Records

Parameter	Limit (mg/L)	Test Level Range	# of Tests Performed	# Of Tests Not Meeting Requirements
Free Chlorine	Minimum 0.1 mg/L	(.12-5.25)	365	0

A minimum of 0.1 milligrams per litre (mg/L) free chlorine residual is required for water entering the distribution system. Tests are normally performed on a daily basis by the waterworks operator and are to be recorded in operation records. This data includes the number of free chlorine residual tests performed, the overall range of free chlorine residual (highest and lowest recorded values) and the number of tests and percentage of results not meeting the minimum requirement of 0.1 mg/L free chlorine residual.

Turbidity – From Water Treatment Plant Records

Parameter	Limit NTU	Test Level Range	# of Tests Not Meeting Requirements	# of Tests Required	# of Tests Performed
Turbidity	1	(.1-1.39)	12	365	365

Chemical – Health Category

All waterworks serving less than 5000 persons are required to submit water samples for SE’s Chemical Health category once every 2 years. The Chemical Health category includes analysis for arsenic, barium, boron, cadmium, chromium, fluoride, lead, nitrate, selenium and uranium.

The last sample for Chemical Health analysis was submitted on March 25,2025. Samples exceeded provincial water quality standards for the following parameters: (

Parameter	Limit MAC	Units	Limit IMA C	Units	Sample Result (s)	Units	# of Samples Exceeding Limit	*Results expressed as average values for communities or waterworks that fluoridate drinking water supplies or those with elevated concentrations of fluoride or nitrates.
Arsenic	10.0	µg/L					0	
Barium	1.0	mg/L					0	
Boron			5.0	mg/L			0	
Bromate	10.0	µg/L					0	
Cadmium	5.0	µg/L					0	
Chlorate	1.0	mg/L					0	
Chlorite	1.0	mg/L					0	
Chromium	50.0	µg/L					0	
Flouride (avg. *)	1.5	mg/L					0	
Lead	10.0	µg/L					0	
Nitrate (avg. *)	45.0	mg/L					0	
Selenium	10.0	µg/L					0	
Uranium	20.0	µg/L					0	

Chemical – Trihalomethanes (THMs)and Haloacetic Acids (HAAs)

Parameter	Limit (mg/L)	Sample Result (average)	Units (mg/L or µg/L)	# of Samples Required	# of Samples Submitted
Trihalomethanes	0.1	1.82	mg/L	4 (1 every 3 months)	4
Haloacetic Acid	0.08	.035	mg/L	4 (1 every 3 months)	4

Note: Only water supplies derived from surface water or groundwater under the influence of surface water are required to monitor for THMs and HAAs. Waterworks using groundwater sources beyond the influence of surface water do not need to report THMs or HAAs since sampling/analysis will not likely have been performed unless otherwise noted in the waterworks permit to operate

General Chemical

Parameter	Aesthetic Objective (mg/L)	Sample Results (average)	Units (mg/L or µg/L)	# of Samples Required	# of Samples Submitted
Alkalinity	500	573	mg/L	1	1
Bicarbonate	No Objective	699	mg/L	1	1
Calcium	No Objective	86	mg/L	1	1
Carbonate	No Objective	0	mg/L	1	1
Chloride	250	174.9	mg/L	1	1
Conductivity	No Objective	3031	mg/L	1	1
Hardness	800	400	mg/L	1	1
Magnesium	200	.10	mg/L	1	1
pH	No Objective	8.0	mg/L	1	1
Sodium	300	587	mg/L	1	1
Sulphate	500	907.3	mg/L	1	1
Total Dissolved Solids	1500	2514	mg/L	1	1

All waterworks serving less than 5000 persons are required to submit water samples for SE's General Chemical category once every two years if a ground water source and once per three months every second year if a surface water or blended surface/groundwater source. The General Chemical category includes analysis for alkalinity, bicarbonate, calcium, carbonate, chloride, conductivity, hardness (as CaCO₃), magnesium, sodium, sulphate and total dissolved solids.

The last sample for General Chemical analysis was required 2025 and submitted on March 24, 2025. The last sets of quarterly samples for General Chemical analysis were required on 2023 and were submitted on June 27,2023. Samples exceeded provincial aesthetic objectives for the General Chemical category for the following parameters:

More information on water quality and sample submission performance may be obtained from:

Town of Lampman
 Box 70, Lampman SK S0C 1N0
 306-487-2462 or Fax 306-487-3212
 lampman@sasktel.net

June 2015 EPB 536D